

Approved body No. 1121

Certificate of constancy of performance

1121-CPR-UK-RA7003

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Flame Armour 60/90/120/240

Product: Fire resisting roller shutter covered by EN 13241-1

Intended use: Fire compartmentation and/or escape routes

Essential characteristics	Performance	Designated technical specification
Resistance to Fire ¹	E60 / E90 / E120 / E240	EN 16034: 2014
Smoke control (only for applications where limitation of smoke spread is required)	NPD	
Ability to release ²	released	
Self Closing (only for self closing fire resistance and/or smoke control doorsets and/or openable windows) ³	C	
Durability of ability to release	NPD	
Durability of self-closing	NPD	

The following documentation has been used in support of the essential characteristics performance stated above:

1. EXAP referenced WF Report No. 416673, classification referenced WF Report No. 416674
2. Tests referenced WF Report Nos. 404452 and 429933
3. Tests referenced WF Report Nos. 404452 and 429933, classification referenced WF Report No. 416674

Certificate of constancy of performance

1121-CPR-UK-RA7003

produced for

**SSS Industrial Doors Ltd
Red Earth Farm,
Plantation Road,
Edgworth,
Bolton
BL7 0DD**

and produced in the manufacturing plant

E/327

This is coded format and the information is held by the Approved Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 16034: 2014

under system 1 of AVCP are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on **25/06/2021** and will remain valid to the date given below as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Valid to: **24/06/2024**

**UK
CA**



Paul Duggan
Certification Manager

**Warringtonfire Testing and Certification Limited
Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK**

Notified body No. 2812

Certificate of constancy of performance

2812-CPR-RA5006

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Flame Armour 60/120/240

Product: Fire resisting roller shutter covered by EN 13241-1

Intended use: Fire compartmentation and/or escape routes

Essential characteristics	Performance	Harmonised technical specification
Resistance to Fire	E60 / E120 / E240	EN 16034: 2014
Smoke control (only for applications where limitation of smoke spread is required)	NPD	
Ability to release	released	
Self Closing (only for self closing fire resistance and/or smoke control doorsets and/or openable windows)	C	
Durability of ability to release	NPD	
Durability of self-closing	NPD	

Certificate of Constancy of Performance

2812-CPR- RA5006

Placed on the Market under the Name of

SSS Industrial Doors Limited
Red Earth Farm, Plantation Road, Turton, Bolton, BL7 0DD

and produced in the manufacturing plant

E/327

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

EN 16034: 2014

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 17/11/2020 and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: **06/11/2022**

ERO Project Reference: **EROWF11124**



Paul Duggan
Certification Manager

